



- ① LOW VOLTAGE COMPARTMENT
- ② CIRCUIT BREAKER COMPARTMENT
- ③ BUSBAR COMPARTMENT
- ④ CABLE COMPARTMENT
- ⑤ 1250A VACUUM CIRCUIT BREAKER
- ⑥ CURRENT TRANSFORMER
- ⑦ EARTHING SWITCH

Tarih-Date	30.08.2022
Çizen-Drawn By	H.UÇ
Kontrol-Checked By	H.UÇ
Onay-Approval by.	A.ÖÇAK

(24kV / 31,5kA / 1250A) OUTGOING FEEDER WITH VCB SWITCHGEAR
--

--

Ölçek / Scale 1:30
